


# System 1

Floor: 3.NP

Elevation: 0,5m above Outdoor Unit



## System Information

Indoor Units	14 of 45
Capacity	100,0%
Total Pipe Length	78,9 m
Indoor Cap. Tot./Sen.	50,99 kW/36,37 kW
Indoor Cap. Heat.	47,34 kW
Building diversity	0%

## Outdoor/Indoor Legend

Model Name (Capacity Code)

\*Room name

- ⊕ Corrected Capacity Tot./Sens./ Heat.
- Rated Capacity Tot./Sens./ Heat.

## Piping Legend

Actual Length

Liquid / Suction Gas diameters

Note: It is the responsibility of the consultant or contractor, to verify and confirm that the equipment selection and system design is correct before installation.

## Branches Legend

a	(x4)
b	(x8)
c	(x1)